



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.  
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.  
 3) EXTEND ALL CPLGS. 5/8" INSIDE.

HEADS	LEFT-.248" SA-455 2:1 S.E. (.216" MIN.)	CS-64-1650-H	REV. 4-22-03	
	RIGHT-.288" SA-455 2:1 S.E. (.235" MIN.)		DATE: 10-23-89	
	SHELL	.250" SA-455	FOR: HANSON STANDARD HORIZ. WATER TANK	
	M.A.W.P. 125 PSIG. @ 210 °F		197.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION IV 2001 ADD. 2002		INSIDE: CEMENT LINED (1583)		
X-RAY: RT-NO / H.L.W.		OUTSIDE: PRIME		
GALLONS: 1650 WT. 3800 LBS.		CAD-"B" UNDER "STD"-SERIES		
SERIAL NO.		BY: E.S.	SCALE: 1/2" = 12"	
N.B.		<b>ROY E. HANSON JR. MFG.</b>		
		1924 COMPTON AVE. LOS ANGELES, CA 90011		