



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) EXTEND ALL CPLG. 5/8" INSIDE.
 3) HYDRO @ 240 PSIG.
 4) 4-1-04 PROOF TEST.

HEADS / SHELL	.166" SA-414-G 2:1 S.E.	CS-30-235-V	REV. 10-6-04
	JOGGLE		DATE: 5-7-92
SHELL / HEADS	.165" SA-414-G	FOR: HANSON STANDARD VERT. HOT WATER TANK	
	M.A.W.P. 160 PSIG. @ 210 °F	58.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION IV 2001 ADD 2003	X-RAY: RT-NO/H.L.W.	INSIDE: CEMENT LINED	
GALLONS: 235	WT. 910 LBS.	OUTSIDE: PRIME	
SERIAL NO.		(220) LEG-ZONE 4-15 KM.	
N.B.		CAD-"B" UNDER "STD"-SERIES	
		BY: J.G.	SCALE: 1"=12"
		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	