



- 2"-3000# HALF CPLG. (3) PLC'S.
- 1"-3000# FULL CPLG.
- 1/2"Ø L.LUG (1) PLC.
- 5.18
- 5.17 TYP.
- RAISED N.PL.
- 60°
- 3/4"
- 60°
- 3/4"
- 1 1/4"
- 1 1/4"-3000# HALF CPLG. (2) PLC'S.
- 15"
- 10"
- 5"
- 12"
- 4"
- 88" O.A.
- 63 3/4" +
- 3 1/2"
- 12 TYP.
- 3/16" x 5.2 TYP. CPLGS.
- 3/16"
- 3/16"
- 5.2
- 11" x 15" M. WAY W/ 3/4" x 4" LG. GR.70 RING
- 7/16" STICK OUT
- 6"
- 2"
- 1"
- 60°
- 3/4" FULL CPLG. (2) PLC'S.
- 3/16" x 5.2
- 3/16"
- 3/16"
- 5.2
- 1 1/4"
- 18 7/8" @ 60° TYP.
- 2"
- 1 1/4"
- 9 7/16" @ 30° TYP.
- 6"
- 11 L.S.

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) EXTEND ALL CPLGS. 5/8" INSIDE.
 3) HYDRO @ 240 PSIG. MIN.
 4) 4-1-04 PROOF TEST.

HEADS	.182" SA-455 2:1 S.E.	CS-36-360-V	REV. 10-6-04
JOGGLE			DATE: 3-26-03
SHELL	.164" SA-414-G	FOR: HANSON STANDARD VERT. HOT WATER TANK	
M.A.W.P.	160 PSIG. @ 210 °F	73.8 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME SECTION	IV 2001 ADD 2003	INSIDE: CEMENT LINED	
X-RAY:	RT-NO / H.L.W.	OUTSIDE: PRIME	
GALLONS:	360	(334) LEG-ZONE 4-15 KM.	
WT.	1145 LBS.	CAD-"B" UNDER "STD"-SERIES	
SERIAL NO.		BY: E.S.	SCALE: 1"=12"
N.B.		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	